

**ADDENDUM #2
BUILDING ENVELOPE REPLACEMENT AT THE
CLACKAMAS COUNTY EMERGENCY OPERATIONS CENTER**

TO: ALL BID DOCUMENT HOLDERS
DATE: June 14, 2016

This Addendum #2 issued prior to receipt of Bids will become part of the Contract documents, superseding the originals to the applicable extent indicated. Bidders shall be responsible for issuing information to those furnishing bids and quotations to them.

CHANGES

The Bid Opening Date has been moved to Tuesday June 21, 2016. The Bid Opening Time remains 2:00 PM with Subcontractor Disclosure Forms due by 4:00 PM.

QUESTIONS AND CLARIFICATIONS

1. Is all the sheathing to be removed? All the sheathing where the siding is to be removed is to be replaced with 1/2" CDX plywood.

All Bidders shall acknowledge receipt and acceptance of this Addendum #2 for the **BUILDING ENVELOPE REPLACEMENT AT THE CLACKAMAS COUNTY EMERGENCY OPERATIONS CENTER** by signing in the space provided and submitting the signed Addendum with the Bid. Bids submitted without this Addendum may be considered informal.

George Marlton – Procurement Division Director

Received, acknowledged, and conditions agreed to this _____ day of _____, 2016.

BIDDER: _____

BY: _____