

**ADDENDUM #2
TO THE BID DOCUMENTS FOR THE WICHITA CENTER PARKING LOT
IMPROVEMENT PROJECT**

TO: ALL BID DOCUMENT HOLDERS

DATE: JULY 21, 2016

This Addendum #2 issued prior to receipt of Bids will become part of the Contract documents, superseding the originals to the applicable extent indicated. Bidders shall be responsible for issuing information to those furnishing bids and quotations to them.

CHANGES

SECTION 3 – BID PROPOSAL, SCHEDULE OF PRICES AND SUBCONTRACTOR FORM

Bid Item #13 is deleted. No new Bid Schedule is being issued.

CLARIFICATION

Bid Item #35 – Underground Storage Tank Removal

According to the North Clackamas School District, the tank was previously used for heating oil and has a 7,500 gallon capacity. When last checked two years ago, the tank was empty (no fuel or water). For the purposes of this bid item, the tank must be removed according to Oregon Department of Environmental Quality regulations. It is assumed the tank can be removed and disposed of at a proper facility and the area backfilled per plan specifications. No removal of contaminated soil is assumed.

If contaminated soil is discovered and/or the decision is made to decommission the tank in place, this will be handled via change order.

All Bidders shall acknowledge receipt and acceptance of this Addendum #2 by signing in the space provided and submitting the signed Addendum with the Bid. Bids submitted without this Addendum may be considered informal.

George Marlton – Procurement Division Director

Received, acknowledged, and conditions agreed to this _____ day of _____, 2016.

BIDDER: _____

BY: _____