



INVITATION TO BID #2017-60  
SPRINGWATER ROAD AT  
CLACKAMAS RIVER BRIDGE ("BID")  
RESPONSE TO CLARIFYING QUESTIONS  
August 22, 2017

Note that these are questions submitted by interested firms to the above referenced solicitation. The below answers are for clarification purposes only and in no way alter or amend the BID as published.

- 1. The bid sheet calls for Item 35: Level 3, 1/2" Dense MHMAC Mixture (Base/ Leveling) and the typical has the base and leveling course Level 3, 3/4" Dense. Which mix do you want for Base course?*

**Answer:** Please use the call out on the bid sheet; Level 3, 1/2-inch Dense MHMAC.

---

End of Clarifying Questions #1