

**ADDENDUM #1
TO THE BID DOCUMENTS FOR THE OTTY STREET REALIGNMENT PROJECT**

TO: ALL BID DOCUMENT HOLDERS
DATE: APRIL 28, 2016

This Addendum #1 issued prior to receipt of Bids will become part of the Contract documents, superseding the originals to the applicable extent indicated. Bidders shall be responsible for issuing information to those furnishing bids and quotations to them.

CHANGES:

The Bid Opening Date has been moved to Wednesday May 18, 2016. The Bid Opening Time remains 2:00 PM with the Sub-Contractor Disclosure Forms due Wednesday May 18, 2016 by 4:00 PM.

SECTION 3 – BID PROPOSAL, SCHEDULE OF PRICES, SUB-CONTRACTOR FORM Remove and replace the Bid Schedule of Prices with the enclosed revised Bid Schedule further identified as Addendum #1. The following changes were made to the Bid Schedule:

Item 24.1 Added Bid Item “General Rock Excavation” (200 CY)
Item 46 Bid Quantity revised to 490 Square Feet
Item 100.1 Added Bid Item “2nd, 3rd, 4th, and 5th Year Plant Establishment”

SECTION 8 – STANDARD SPECIFICATIONS AND SPECIAL PROVISIONS

The following changes have been made to the Special Provisions:

00759.90 Payment – Add the following at the end of this section:

Aggregate base within the road section (i.e. under “Concrete Curb and gutter” or “Concrete Traffic Separator”) shall be 1” – 0 and will be paid as “aggregate Base” under 00641.90. See plans for depth requirements.

Crushed rock required under Type “C” planter curbs, sidewalks and driveways shall be 3/4” – 0 and will be considered incidental to the appropriate bid item. See plans for depth requirements.

00990.00 Scope – Add the following to the end of this section:

Prior to beginning installation of traffic signals or pedestrian control devices, Contractor shall coordinate a pre-construction meeting with ODOT, County Signal Engineer, Project Inspectors, Contractor, and Contractor’s Electrician.

SECTION 9 – PLANS, DRAWINGS, AND EXHIBITS

The following Plan Sheets have been revised:

Sheets TS-1, TS-3, TS-5 Revised Sheets are Stamped and Signed
Sheets IC-1 through IC-16 Revised Sheets are Stamped and Unsigned

Note: The revised interconnect sheets (IC-1 through IC-16) included with this addendum have been updated from the Bid Set and though they are currently unsigned, **should** be used in preparing bids for this project. They will be signed prior to construction, once final approval is given.

All Bidders shall acknowledge receipt and acceptance of this Addendum #1 by signing in the space provided and submitting the signed Addendum with the Bid. Bids submitted without this Addendum may be considered informal.

George Marlton – Procurement Division Director

Received, acknowledged, and conditions agreed to this _____ day of _____, 2016.

BIDDER: _____

BY: _____