



NOTES

1. SPECIFICATIONS FOR CONCRETE AND MISCELLANEOUS MATERIALS USED IN CONSTRUCTION SHALL CONFORM TO CURRENT OREGON STANDARD SPECIFICATIONS FOR CONSTRUCTION.
2. CONCRETE SHALL HAVE A MINIMUM COMPRESSIVE STRENGTH OF 3300 PSI IN 28 DAYS, 2" TO 4" SLUMP.
3. WEEP HOLES ARE NOT ALLOWED.
4. EXPANSION JOINTS, MAX. 45' SPACING AND AT BEGINNING AND END OF CURVES OR AS DIRECTED.
5. CONTRACTION JOINTS, MAX. 12' SPACING AND AT LOCATIONS AS DIRECTED.
6. EXPOSURE MAY BE REDUCED TO 4" EXPOSURE TO ACCOMMODATE HIGH TRAFFIC USE UPON COUNTY APPROVAL.
7. SEE NOTES ON DETAIL S100.

<i>REVISION</i>	<i>DATE</i>	<i>BY</i>	DEPARTMENT OF TRANSPORTATION AND DEVELOPMENT	<i>APPROVAL DATE:</i> 2/1/13	<i>SCALE:</i> N.T.S.	<i>STANDARD DRAWING</i>
EDIT NOTE 1	12/12	RN		150 BEAVERCREEK ROAD OREGON CITY, OR 97045		MOUNTABLE CURB